



SPECIFICATIONS

1. MATERIAL TO BE A MINIMUM OF 16 OZ. VINYL LAMINATED POLYESTER OR OF A MATERIAL WITH AN EQUIVALENT STRENGTH. BANNER SHALL BE MADE FROM ONE CONTINUOUS PIECE OF MATERIAL.
2. ALL GROMMETS TO BE #5 (5/8") SPUR

INSTALLATION

1. BANNER TO BE INSTALLED USING ETPL SUPPLIED SNAP HOOKS TO 3/8" 180 GRADE GUY WIRE. BANNER CORNERS TO BE SECURED USING 3/8" GUY GRIPS, SUPPLIED BY ETPL.
2. THIS STANDARD IS A MINIMUM REQUIREMENT FOR BANNERS TO BE INSTALLED ON ERIE THAMES POWERLINES' SYSTEM.

DISCLAIMER

1. ERIE THAMES POWERLINES WILL INSTALL BANNERS TO MAINTAIN PUBLIC SAFETY AND INTEGRITY OF THE BANNER. ERIE THAMES POWERLINES WILL NOT BE LIABLE FOR DAMAGES TO THE BANNER.



ERIE THAMES
143 BELL STREET
INGERSOLL, ONTARIO
N5C 2N9
PH: 519-485-1820
FX: 519-485-5830

TITLE:

**ERIE THAMES POWERLINES
BANNER DETAIL
TYPICAL STANDARD**

DRAWN BY
EAW

SIZE
A

FILE NAME
Typical Banner Detail_AUG2012

REVISION
03

APPROVED BY
Cd

SCALE
NTS

DATE
AUG 10, 2012

PAGE
1